



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

December 10, 2010

In reply refer to:
Adai: 248636

Mr. A.C. Entingh
Head, Environmental Compliance Department
AC/S Environmental Security
U.S. Marine Corps Base
P.O. Box 555008
Camp Pendleton, CA 92055-5008

Dear Mr. Entingh:

**SUBJECT: REVIEW OF MONITORING REPORTS FOR SEWAGE TREATMENT
PLANT 9 (STP #9)**



The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the October 2010 monthly monitoring report submitted by the United States Marine Corps (USMC) in accordance with the Monitoring and Reporting Program of Order No. 98-04.

The San Diego Water Board identified the following violation of Prohibition A.1 of Order No. 98-04:

The USMC reported that a spill of 1,000 gallons of tertiary disinfected wastewater occurred from an effluent line near Red Beach on October 8, 2010, which was damaged by Southern California Edison's maintenance crew. The USMC, however, reported that repairs were completed on the damaged effluent line.

The next monitoring report to be submitted is the November 2010 monthly monitoring report due by December 30, 2010.

California Environmental Protection Agency



Mr. Entingh

- 2 -

December 10, 2010

For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or via email at adai@waterboards.ca.gov.

PLEASE INCLUDE "248636:ADAI" IN THE SUBJECT LINE OF FUTURE CORRESPONDANCE.

Sincerely,



Fisayo Osibodu
Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure ID: 376835
Violation ID: 887101